

PROFORMA REGARDING SAFE DRINKING WATER AND
SANITARY CONDITION CERTIFICATE

Date: 02.03.2022No. TC8840220000001F508

It is certified that an inspection team headed by Mv. Brajesh Kishor Prasad; Technical
(Name of Officers with designation)
Managers
from D. W. and Sanitation Division (Name of Department/Office) inspected the
ST. PAUL'S SCHOOL; HURHURU ROAD; HAZARIBAGH
(Name and Address of the
(JHARKHAND)
School) on 28.02.2022 and found that the ST. PAUL'S SCHOOL
(Name of school) has safe drinking water

facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation
condition in the school building and the campus as per the norms prescribed by the Central/State/ Union
Territory Government


The above valid for a period of One Year Only.

Signature with Seal : [Signature]
02.03.2022
Name : Abhishek Kumar
Designation : Authorised Signatory
District Level Water Testi.g Laboratory
Hazaribaagh, Jharkhand

To

ST. PAUL'S SCHOOL
HURHURU ROAD
HAZARIBAGH (JHARKHAND)
(Name and Address of the Institution)

District Level Water Testing Laboratory
Office of the Executive Engineer, Drinking Water and Sanitation Division,
Hazaribagh-825301, Jharkhand, India. Contact No.-7004844353
Email: dlwtl.hazaribagh@gmail.com

Doc No.: HB-DLWTL-QP-4-F-19 Issue No.: 01 Revision No.: 01 Date :16.04.2021	Test Analysis Report	 TC-8840
--------------------------------------------------------------------------------------	-----------------------------	------------------------------------------------------------------------------------------------

Issued to :- ST. PAUL'S SCHOOL HURHURU ROAD, HAZARIBAGH (JHARKHAND)	Sample Code:-220302GWP00001 Report ID :- TC8840220000000IF508 Date of Issue: - 02/03/2022 Customer Reference No. : - HB-DLWTL708
Sample Particulars Sample Name/Description: - G.W. Sample Quantity : - 01 L Sample pkg. Condition : - GOOD Sample No. : 01 No.	Details of Sampling Customer Date of sampling : - 28/02/2022 Sample Receive date: 28/02/2022 Sample collected by: -: CUSTOMER Sampling Location: FINAL OUTLET

Test started on :-		28/02/2022		Test Result		Test completed on :- 02/03/2022	
Sl. No.	Tested Parameter	Unit	Results	Method	Specification as per IS 10500 : 2012 (Second Revision)		
					Acceptable Limit	Permissible Limit (Absence of Alternate source)	
1	pH	-	7.82	APHA 23 rd Ed.2017-4500-H B, (Electrometric method)	6.5 - 8.5	No relaxation	
2	Turbidity	NTU	3.4	APHA 23 rd Ed.2017-2130 B, (Nephelometric method)	1	5	
3	Total Alkalinity as CaCO ₃	mg/l	290	APHA 23 rd Ed.2017-2320 B, (Titration method)	200	600	
4	Calcium as (Ca)	mg/l	69.28	APHA 23 rd Ed.2017-3500 Ca B, (EDTA Titration method)	75	200	
5	Magnesium as Mg	mg/l	18.21	APHA 23 rd Ed.2017-3500-Mg B, (Calculation method)	30	100	
6	Total Hardness as CaCO ₃	mg/l	250	APHA 23 rd Ed.2017-2340 C, (EDTA Titration method)	200	600	
7	Fluoride as (F)	mg/l	0.88	APHA 23 rd Ed.2017-4500 F- C, (Ion selective electrode method)	1.0	1.5	


Remarks:-Submitted Sample of Water according to above parameters is fit for Consumption :- Yes / No ()
 Specific contractual notes :-

- ◆ The results listed refer only to the tested sample and applicable parameter.
- ◆ This report shall not be reproduced except in full without approval of the laboratory.
- ◆ This report results apply to the sample as received.
- ◆ This report results relate only to the items tested.
- ◆ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ◆ Tested Sample shall be retained up to seven days from the date of issue of the test report.
- ◆ The liability of the laboratory is limited to the invoiced amount.
- ◆ All disputes are subjected to the Ranchi Jurisdiction.
- ◆ NOTE:- BDL=Below Detection Limit

Officer
 02.03.2022

Authorised Signatory
District Level Water Testing Laboratory
Hazaribagh, Jharkhand

.....End of the report.....

Doc No.: HB-DLWTL-QP-4-F-19 Issue No.: 01 Revision No.: 00 Date :01.03.2019	Test Analysis Report	
--------------------------------------------------------------------------------------	-----------------------------	-------------------------------------------------------------------------------------

Issued to : - ST. PAUL'S SCHOOL HURHURU ROAD, HAZARIBAGH (JHARKHAND)	Sample Code:- 220302GWP00002 Report ID : - TC8840220000000IF508 Date of Issue: - 03/02/2022 Customer Reference No. : - HB-DLWTL-708
Sample Particulars	Details of Sampling
Sample Name/Description: - G.W. Sample Quantity : - 01 L Sample pkg. Condition : - GOOD Sample No. : 02 No.	Customer Date of sampling : - 28/02/2022 Sample Receive date: 28/02/2022 Sample collected by: -: CUSTOMER Sampling Location: FINAL OUTLET

Test Result						
Test started on: -	28/02/2022	Test completed on :-	02/03/2022			
Sl. No.	Tested Parameter	Unit	Results	Method	Specification as per IS 10500 : 2012 (Second Revision) Amendment - 2015	
					Acceptable Limit	Permissible Limit (Absence of Alternate source)
1	Total Coliform	CFU/100 mL	NIL	APHA 23 rd Ed.2017- 9222B (Membrane Filter Technique)	Shall not be detectable in any 100 mL sample	
2	Thermotolerant (Fecal) Coliform/ E.Coli	CFU/100 mL	NIL	APHA 23 rd Ed.2017- 9222D (Membrane Filter Technique)	Shall not be detectable in any 100 mL sample	

Remarks:-Submitted Sample of Water according to above parameters is fit for Consumption :- Yes / No ()

Specific contractual notes: -

- ◆ The results listed refer only to the tested sample and applicable parameter.
- ◆ This report shall not be reproduced except in full without approval of the laboratory.
- ◆ This report results apply to the sample as received.
- ◆ This report results relate only to the items tested.
- ◆ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ◆ Tested Sample shall be retained up to seven days from the date of issue of the test report.
- ◆ The liability of the laboratory is limited to the invoiced amount.
- ◆ All disputes are subjected to the Ranchi Jurisdiction.
- ◆ NOTE - BDL=Below Detection Limit : TNTC = Too Numerous To Count.

[Signature]
 02.03.2022

Authorised Signatory
District Level Water Testing Laboratory
hazaribaagh, Jharkhand

.....End of the report.....